SCS Global Services does hereby certify that an independent assessment has been conducted on behalf of:

MAPEI Corporation

1144 E Newport Center Drive, Deerfield Beach, FL, United States

For the following product(s):

Accessories:

Idrostop, Idrostop B25, Mapeband, Mapeband TPE, Mapecontact MRT, Mapecontact SRT, Mapeguard PC, Mapeguard ST, Mapeguard WP ST, Mapeguard PIC, Mapeguard POC, Mapeguard VC, Ultrabond Landscape Tape, Ultrabond Turf Tape

The product(s) meet(s) all of the necessary qualifications to be certified for the following claim(s):



Indoor Air Quality Certified to SCS-EC10.3-2014 V4.0

Conforms to the CDPH/EHLB Standard Method (CA 01350) v1.2-2017 for the private office, school classroom, and single-family residence parameters.¹

¹ Modeled as Flooring

Measured Concentration of Total Volatile Organic Compounds (TVOC): Less than/equal to 0.5 mg/m3 (in compliance with CDPH/EHLB Standard Method v1.2-2107)

Registration # SCS-IAQ-06774

Valid from: March 23, 2021 to March 22, 2022







Stanley Mathuram, PE, Vice President SCS Global Services

2000 Powell Street, Ste. 600, Emeryville, CA 94608 USA